

# CALCULATION SUMMARY

Project Name : Westdell - CRU #1B

Project Location: 1300 Fanshawe Pk Rd East

Contract No. : 062-040424

City: London, Ontario

## Design Areas

Design Area Name	Calc. Mode (Model)	Occupancy	Area of Application	Total Water	Pressure @ Source	Min. Density	Min. Pressure	Min. Flow	Calculated Heads	Hose Streams	Margin To Source
			(ft <sup>2</sup> )	(gpm)	(psi)	(gpm/ft <sup>2</sup> )	(psi)	(gpm)	#	(gpm)	(psi)
1	Demand (HW)	Ord. Grp. 2	1500	561	Required 35.8	0.2	13.5	20.6	15	250	31.5



# HYDRAULIC CALCULATIONS for

---

## Job Information

Project Name : Westdell - CRU #1B

Contract No. : 062-040424

City: London, Ontario

Project Location: 1300 Fanshawe Pk Rd East

Date: 4/4/2024

---

## Contractor Information

Name of Contractor: SDC

Address: 23 Turnbull Drive

City: Brantford, Ontario N3T 0K4

Phone Number: 226-388-1503

E-mail: jhayhurst@hotmail.ca

Name of Designer: JSH

Authority Having Jurisdiction: Local Bldg Dept.

---

## Design

Remote Area Name	1
Remote Area Location	Retail Area
Occupancy Classification	Ord. Grp. 2
Density (gpm/ft <sup>2</sup> )	0.2
Area of Application (ft <sup>2</sup> )	1500
Coverage per Sprinkler (ft <sup>2</sup> )	103
Number of Calculated Sprinklers	15
In-Rack Demand (gpm)	0
Special Heads	
Hose Streams (gpm)	250
Total Water Required (incl. Hose Streams) (gpm)	561
Required Pressure at Source (psi)	35.8
Type of System	Wet
Volume - Entire System (gal)	1962.3 gal

---


## Water Supply Information

Date	Nov.2015
Location	1300 Fanshawe Pk Rd E
Source	W1

---

## Notes

### Diagram for Design Area : 1 (Optimized Hvdraulic Simplified)



## Hydraulic Analysis for : 1

### Calculation Info

Calculation Mode	Demand
Hydraulic Model	Hazen-Williams
Fluid Name	Water @ 60F (15.6C)
Fluid Weight, (lb/ft <sup>3</sup> )	N/A for Hazen-Williams calculation.
Fluid Dynamic Viscosity, (lb-s/ft <sup>2</sup> )	N/A for Hazen-Williams calculation.

### Water Supply Parameters

Supply 1 : W1

Flow (gpm)	Pressure (psi)
0	68
1160	65
1840	64

### Supply Analysis

Node at Source	Static Pressure (psi)	Residual Pressure (psi)	Flow (gpm)	Available Pressure (psi)	Total Demand (gpm)	Required Pressure (psi)
W1	68	65	1160	67.2	561	35.8

### Hoses

Inside Hose Flow / Standpipe Demand (gpm)	100
Outside Hose Flow (gpm)	0
Additional Outside Hose Flow (gpm)	150
Other (custom defined) Hose Flow (gpm)	0
<hr style="border-top: 1px dashed black;"/>	
Total Hose Flow (gpm)	250


### Sprinklers

Ovehead Sprinkler Flow (gpm)	311
InRack Sprinkler Flow (gpm)	0
Other (custom defined) Sprinkler Flow (gpm)	0
<hr style="border-top: 1px dashed black;"/>	
Total Sprinkler Flow (gpm)	311

### Other

Required Margin of Safety (psi)	0
W1 - Pressure (psi)	35.8
W1 - Flow (gpm)	411
Demand w/o System Pump(s)	N/A

### Hydraulic Analysis for : 1



## Hydraulic Analysis for : 1

### Graph Labels

Label	Description	Values	
		Flow (gpm)	Pressure (psi)
S1	Supply point #1 - Static	0	68
S2	Supply point #2	1160	65
S3	Supply point #3	1840	64
D1	Elevation Pressure	0	10.4
D2	System Demand	411	35.8
D3	System Demand + Add.Out.Hose	561	35.8

### Curve Intersections & Safety Margins

Curve Name	Intersection		Safety Margin	
	Pressure (psi)	Flow (gpm)	Pressure (psi)	@ Flow (gpm)
Supply	67	634.3	31.5	561

### Open Heads

Head Ref.	Head Type	Coverage	K-Factor	Required			Calculated		
				Density	Flow	Pressure	Density	Flow	Pressure
		(ft <sup>2</sup> )	(gpm/psi <sup>1/2</sup> )	(gpm/ft <sup>2</sup> )	(gpm)	(psi)	(gpm/ft <sup>2</sup> )	(gpm)	(psi)
A1	Overhead Sprinkler	103	5.6	0.2	20.6	13.5	0.202	20.9	13.9
A10	Overhead Sprinkler	103	5.6	0.2	20.6	13.5	0.202	20.8	13.8
A11	Overhead Sprinkler	103	5.6	0.2	20.6	13.5	0.203	20.9	14
A12	Overhead Sprinkler	103	5.6	0.2	20.6	13.5	0.201	20.7	13.7
A13	Overhead Sprinkler	103	5.6	0.2	20.6	13.5	0.201	20.7	13.6
A14	Overhead Sprinkler	103	5.6	0.2	20.6	13.5	0.201	20.7	13.6
A15	Overhead Sprinkler	103	5.6	0.2	20.6	13.5	0.203	20.9	13.9
A2	Overhead Sprinkler	103	5.6	0.2	20.6	13.5	0.2	20.6	13.6
A3	Overhead Sprinkler	103	5.6	0.2	20.6	13.5	0.2	20.6	13.5
A4	Overhead Sprinkler	103	5.6	0.2	20.6	13.5	0.2	20.6	13.6
A5	Overhead Sprinkler	103	5.6	0.2	20.6	13.5	0.202	20.8	13.8
A6	Overhead Sprinkler	103	5.6	0.2	20.6	13.5	0.203	20.9	13.9

A7	Overhead Sprinkler	103	5.6	0.2	20.6	13.5	0.2	20.6	13.6
A8	Overhead Sprinkler	103	5.6	0.2	20.6	13.5	0.2	20.6	13.5
A9	Overhead Sprinkler	103	5.6	0.2	20.6	13.5	0.2	20.6	13.6

### Node Data

Node# Elev	Type Hgroup	K-Fact. Open/Closed	Discharge Overdischarge	Coverage Density	Tot. Pres. Elev. Pres.	Req. Pres. Req. Discharge
ft		gpm/psi <sup>1/2</sup>	gpm gpm	ft <sup>2</sup> gpm/ft <sup>2</sup>	psi psi	psi gpm
A3 17.92	Overhead Sprinkler HEAD	5.6 Open	20.6 0	103 0.2	13.5 -10.4	13.5 20.6
A8 17.92	Overhead Sprinkler HEAD	5.6 Open	20.6 0.0	103 0.2	13.5 -10.4	13.5 20.6
A4 17.92	Overhead Sprinkler HEAD	5.6 Open	20.6 0.0	103 0.2	13.6 -10.4	13.5 20.6
A2 17.92	Overhead Sprinkler HEAD	5.6 Open	20.6 0.0	103 0.2	13.6 -10.4	13.5 20.6
A9 17.92	Overhead Sprinkler HEAD	5.6 Open	20.6 0.0	103 0.2	13.6 -10.4	13.5 20.6
A7 17.92	Overhead Sprinkler HEAD	5.6 Open	20.6 0.0	103 0.2	13.6 -10.4	13.5 20.6
A13 17.92	Overhead Sprinkler HEAD	5.6 Open	20.7 0.1	103 0.201	13.6 -10.4	13.5 20.6
A14 17.92	Overhead Sprinkler HEAD	5.6 Open	20.7 0.1	103 0.201	13.6 -10.4	13.5 20.6
A12 17.92	Overhead Sprinkler HEAD	5.6 Open	20.7 0.1	103 0.201	13.7 -10.4	13.5 20.6
A5 17.92	Overhead Sprinkler HEAD	5.6 Open	20.8 0.2	103 0.202	13.8 -10.4	13.5 20.6
A10 17.92	Overhead Sprinkler HEAD	5.6 Open	20.8 0.2	103 0.202	13.8 -10.4	13.5 20.6
A1 17.92	Overhead Sprinkler HEAD	5.6 Open	20.9 0.3	103 0.202	13.9 -10.4	13.5 20.6
A6 17.92	Overhead Sprinkler HEAD	5.6 Open	20.9 0.3	103 0.203	13.9 -10.4	13.5 20.6
A15 17.92	Overhead Sprinkler HEAD	5.6 Open	20.9 0.3	103 0.203	13.9 -10.4	13.5 20.6
A11 17.92	Overhead Sprinkler HEAD	5.6 Open	20.9 0.3	103 0.203	14 -10.4	13.5 20.6
057 17.67	Node NODE				14.4 -10.3	
066 17.67	Node NODE				14.4 -10.3	
056 17.67	Node NODE				14.4 -10.3	
058 17.67	Node NODE				14.4 -10.3	
065 17.67	Node NODE				14.4 -10.3	
067 17.67	Node NODE				14.4 -10.3	
080 17.67	Node NODE				14.4 -10.3	
079 17.67	Node NODE				14.5 -10.3	
081 17.67	Node NODE				14.5 -10.3	
055 17.67	Node NODE				14.7 -10.3	



### Node Data

Node# Elev	Type Hgroup	K-Fact. Open/Closed	Discharge Overdischarge	Coverage Density	Tot. Pres. Elev. Pres.	Req. Pres. Req. Discharge
ft		gpm/psi <sup>1/2</sup>	gpm gpm	ft <sup>2</sup> gpm/ft <sup>2</sup>	psi psi	psi gpm
064 17.67	Node NODE				14.7 -10.3	
001 17.67	Node NODE				14.7 -10.3	
068 17.67	Node NODE				14.7 -10.3	
078 17.67	Node NODE				14.8 -10.3	
082 17.67	Node NODE				14.8 -10.3	
006 14.67	Node NODE				18.7 -9	
008 14.67	Node NODE				18.7 -9	
009 14.67	Node NODE				18.9 -9	
010 14.67	Node NODE				19.1 -9	
011 14.67	Node NODE				19.3 -9	
012 14.67	Node NODE				19.5 -9	
013 14.67	Node NODE				19.5 -9	
014 14.67	Node NODE				19.6 -9	
015 14.67	Node NODE				19.6 -9	
016 14.67	Node NODE				19.6 -9	
040 14.67	Node NODE				21.5 -9	
039 14.67	Node NODE				21.5 -9	
038 14.67	Node NODE				21.6 -9	
037 14.67	Node NODE				21.6 -9	
036 14.67	Node NODE				21.7 -9	
030 14.67	Node NODE				22 -9	
031 14.67	Node NODE				22 -9	
032 14.67	Node NODE				22 -9	
033 14.67	Node NODE				22 -9	
034 14.67	Node NODE				22 -9	

### Node Data

Node# Elev	Type Hgroup	K-Fact. Open/Closed	Discharge Overdischarge	Coverage Density	Tot. Pres. Elev. Pres.	Req. Pres. Req. Discharge
ft		gpm/psi <sup>1/2</sup>	gpm gpm	ft <sup>2</sup> gpm/ft <sup>2</sup>	psi psi	psi gpm
035 14.67	Node NODE				22.1 -9	
117 3.5	Node NODE				28.5 -4.1	
121-O 0.54	Node NODE				30 -2.8	
121-I -2.5	Node NODE				33.7 -1.5	
122 -5.33	Node NODE				34.9 -0.3	
127-O -6	Node NODE				35.6 0	
127-I -6	Node NODE				35.6 0	
128-O -6	Node NODE				35.7 0	
128-I -6	Node NODE				35.7 0	
130-O -6	Node NODE				35.7 0	
130-I -6	Node NODE				35.7 0	
H1 -6	Inside Hose HOSE		100		35.8 0	100
W1 -6	Supply SUPPLY		-411		35.8 0	

**PIPE INFORMATION**

Node 1 Node 2	Elev 1 Elev 2	K-Factor 1 K-Factor 2	Flow added (q) Total flow (Q)	Nominal ID Actual ID	Fittings quantity x (name) = length	L F T	C Factor Pf per ft	total (Pt) elev (Pe) frict (Pf)	NOTES
	(ft)	(gpm/psi <sup>1/2</sup> )	(gpm)	(in)	(ft)	(ft)	(psi)	(psi)	

**Path No: 1**

A3 057	17.92 17.67	5.6	20.6 20.6	1 1.049	1x(us.Tee-Br)=5	0.25 5 5.25	120 0.137	13.5 0.1 0.7	
057 058	17.67 17.67		-9.6 11	1.5 1.68		10 0 10	120 0.0044	14.4 0 0.0	
058 001	17.67 17.67		20.6 31.7	1.5 1.68		10 0 10	120 0.0307	14.4 0 0.3	
001 006	17.67 14.67		20.9 52.5	1.5 1.68	2x(us.Tee-Br)=19.68	14.79 19.68 34.47	120 0.0782	14.7 1.3 2.7	
006 008	14.67 14.67		0 52.5	3 3.26		10.27 0 10.27	120 0.0031	18.7 0 0.0	
008 009	14.67 14.67		52.6 105.2	3 3.26		10.27 0 10.27	120 0.0112	18.7 0 0.1	
009 010	14.67 14.67		53 158.2	3 3.26		9.51 0 9.51	120 0.0239	18.9 0 0.2	
010 011	14.67 14.67		-23.1 135.1	3 3.26		12.25 0 12.25	120 0.0178	19.1 0 0.2	
011 012	14.67 14.67		-22.5 112.6	3 3.26		12.25 0 12.25	120 0.0127	19.3 0 0.2	
012 013	14.67 14.67		-23 89.6	3 3.26		9.44 0 9.44	120 0.0083	19.5 0 0.1	
013 014	14.67 14.67		-22.5 67.1	3 3.26		10.23 0 10.23	120 0.0049	19.5 0 0.0	
014 015	14.67 14.67		-22.2 44.8	3 3.26		10.23 0 10.23	120 0.0023	19.6 0 0.0	
015 016	14.67 14.67		-22.1 22.8	3 3.26	1x(us.Tee-Br)=20.16	10.23 20.16 30.39	120 0.0007	19.6 0 0.0	
016 030	14.67 14.67		0 22.8	1.5 1.68	3x(us.Tee-Br)=29.53	110.2 29.53 139.73	120 0.0167	19.6 0 2.3	
030 031	14.67 14.67		0 22.8	4 4.26		10.23 0 10.23	120 0.0002	22 0 0	
031 032	14.67 14.67		22.1 44.8	4 4.26		10.23 0 10.23	120 0.0006	22 0 0	

### PIPE INFORMATION

Node 1 Node 2	Elev 1 Elev 2	K-Factor 1 K-Factor 2	Flow added (q) Total flow (Q)	Nominal ID Actual ID	Fittings quantity x (name) = length	L F T	C Factor Pf per ft	total (Pt) elev (Pe) frict (Pf)	NOTES
	(ft)	(gpm/psi <sup>1/2</sup> )	(gpm)	(in)	(ft)	(ft)	(psi)	(psi)	

**Path No: 1**

032	14.67		22.2	4		10.23	120	22	
033	14.67		67.1	4.26		0	0.0013	0	
						10.23		0.0	
033	14.67		22.5	4		9.44	120	22	
034	14.67		89.6	4.26		0	0.0023	0	
						9.44		0.0	
034	14.67		23	4	1x(us.Tee-Br)=26.33	1.69	120	22	
035	14.67		112.6	4.26		26.33	0.0035	0	
						28.02		0.1	
035	14.67		198.3	4	1x(us.Tee-Br)=26.33	28.92	120	22.1	
117	3.5		311	4.26	1x(us.90)=13.17	39.5	0.0227	4.8	
						68.42		1.6	
117	3.5		0	6	1x(us.Tee-Br)=37.72	12.46	120	28.5	
121-O	0.54		311	6.357	2x(us.90)=35.21	72.93	0.0032	1.3	
						85.38		0.3	
121-O	0.54		0	6		3.04		30	AmesC300N
121-I	-2.5		311	0		0	0.7686	1.3	***
						3.04		2.3	
121-I	-2.5		0	6		2.83	120	33.7	
122	-5.33		311	6.357		0	0.0032	1.2	
						2.83		0	
122	-5.33		0	8	3x(us.45)=38.58	494.84	150	34.9	
127-O	-6		311	7.98	1x(us.90)=25.72	64.3	0.0007	0.3	
						559.14		0.4	
127-O	-6		0	8		0.96		35.6	Gate A2360
127-I	-6		311	0		0	0.0023	0	***
						0.96		0	
127-I	-6		0	8		60.29	150	35.6	
128-O	-6		311	7.98		0	0.0007	0	
						60.29		0.0	
128-O	-6		0	8		0.96		35.7	Gate A2360
128-I	-6		311	0		0	0.0023	0	***
						0.96		0	
128-I	-6		0	8	1x(us.90)=25.72	86.51	150	35.7	
130-O	-6		311	7.98		25.72	0.0007	0	
						112.23		0.1	
130-O	-6		0	8		0.96		35.7	Gate A2360
130-I	-6		311	0		0	0.0023	0	***
						0.96		0	
130-I	-6		0	8		3.33	150	35.7	
H1	-6		311	7.98		0	0.0007	0	
						3.33		0	
H1	-6		100	8		0.67	150	35.8	
W1	-6		411	7.98		0	0.0012	0	
						0.67		0	
<b>W1</b>								<b>35.8</b>	

### PIPE INFORMATION

Node 1 Node 2	Elev 1 Elev 2	K-Factor 1 K-Factor 2	Flow added (q) Total flow (Q)	Nominal ID Actual ID	Fittings quantity x (name) = length	L F T	C Factor Pf per ft	total (Pt) elev (Pe) frict (Pf)	NOTES
	(ft)	(gpm/psi <sup>1/2</sup> )	(gpm)	(in)	(ft)	(ft)	(psi)	(psi)	

**Path No: 2**

A8 066	17.92 17.67	5.6	20.6 20.6	1 1.049	1x(us.Tee-Br)=5	0.25 5 5.25	120 0.1371	13.5 0.1 0.7	
066 067	17.67 17.67		-9.5 11.1	1.5 1.68		10 0 10	120 0.0044	14.4 0 0.0	
067 068	17.67 17.67		20.6 31.8	1.5 1.68		10 0 10	120 0.0308	14.4 0 0.3	
068 008	17.67 14.67		20.9 52.6	1.5 1.68	2x(us.Tee-Br)=19.68	14.79 19.68 34.47	120 0.0785	14.7 1.3 2.7	
<b>008</b>								<b>18.7</b>	

**Path No: 3**

A4 056	17.92 17.67	5.6	20.6 20.6	1 1.049	1x(us.Tee-Br)=5	0.25 5 5.25	120 0.1373	13.6 0.1 0.7	
056 055	17.67 17.67		9.6 30.2	1.5 1.68		10 0 10	120 0.028	14.4 0 0.3	
055 040	17.67 14.67		20.8 51	1.5 1.68	2x(us.Tee-Br)=19.68	55.41 19.68 75.1	120 0.0741	14.7 1.3 5.6	
040 039	14.67 14.67		0 51	4 4.26		10.27 0 10.27	120 0.0008	21.5 0 0	
039 038	14.67 14.67		51 102	4 4.26		10.27 0 10.27	120 0.0029	21.5 0 0.0	
038 037	14.67 14.67		50.8 152.8	4 4.26		9.51 0 9.51	120 0.0061	21.6 0 0.1	
037 036	14.67 14.67		23.1 175.9	4 4.26		12.25 0 12.25	120 0.0079	21.6 0 0.1	
036 035	14.67 14.67		22.5 198.3	4 4.26	1x(us.Tee-Br)=26.33	10.56 26.33 36.89	120 0.0099	21.7 0 0.4	
<b>035</b>								<b>22.1</b>	

**Path No: 4**

A2 058	17.92 17.67	5.6	20.6 20.6	1 1.049	1x(us.Tee-Br)=5	0.25 5 5.25	120 0.1374	13.6 0.1 0.7	
<b>058</b>								<b>14.4</b>	

### PIPE INFORMATION

Node 1 Node 2	Elev 1 Elev 2	K-Factor 1 K-Factor 2	Flow added (q) Total flow (Q)	Nominal ID Actual ID	Fittings quantity x (name) = length	L F T	C Factor Pf per ft	total (Pt) elev (Pe) frict (Pf)	NOTES
	(ft)	(gpm/psi <sup>1/2</sup> )	(gpm)	(in)	(ft)	(ft)	(psi)	(psi)	

**Path No: 5**

A9 065	17.92 17.67	5.6	20.6 20.6	1 1.049	1x(us.Tee-Br)=5	0.25 5 5.25	120 0.1374	13.6 0.1 0.7	
065 064	17.67 17.67		9.5 30.1	1.5 1.68		10 0 10	120 0.0279	14.4 0 0.3	
064 039	17.67 14.67		20.8 51	1.5 1.68	2x(us.Tee-Br)=19.68	55.41 19.68 75.1	120 0.074	14.7 1.3 5.6	
<b>039</b>								<b>21.5</b>	

**Path No: 6**

A7 067	17.92 17.67	5.6	20.6 20.6	1 1.049	1x(us.Tee-Br)=5	0.25 5 5.25	120 0.1375	13.6 0.1 0.7	
<b>067</b>								<b>14.4</b>	

**Path No: 7**

A13 080	17.92 17.67	5.6	20.7 20.7	1 1.049	1x(us.Tee-Br)=5	0.25 5 5.25	120 0.1377	13.6 0.1 0.7	
080 081	17.67 17.67		-9.2 11.4	1.5 1.68		10 0 10	120 0.0046	14.4 0 0.0	
081 082	17.67 17.67		20.7 32.1	1.5 1.68		10 0 10	120 0.0315	14.5 0 0.3	
082 009	17.67 14.67		20.9 53	1.5 1.68	2x(us.Tee-Br)=19.68	14.79 19.68 34.47	120 0.0797	14.8 1.3 2.7	
<b>009</b>								<b>18.9</b>	

**Path No: 8**

A14 079	17.92 17.67	5.6	20.7 20.7	1 1.049	1x(us.Tee-Br)=5	0.25 5 5.25	120 0.138	13.6 0.1 0.7	
079 078	17.67 17.67		9.2 29.9	1.5 1.68		10 0 10	120 0.0276	14.5 0 0.3	
078 038	17.67 14.67		20.9 50.8	1.5 1.68	2x(us.Tee-Br)=19.68	55.41 19.68 75.1	120 0.0735	14.8 1.3 5.5	
<b>038</b>								<b>21.6</b>	

### PIPE INFORMATION

Node 1 Node 2	Elev 1 Elev 2	K-Factor 1 K-Factor 2	Flow added (q) Total flow (Q)	Nominal ID Actual ID	Fittings quantity x (name) = length	L F T	C Factor Pf per ft	total (Pt) elev (Pe) frict (Pf)	NOTES
	(ft)	(gpm/psi <sup>1/2</sup> )	(gpm)	(in)	(ft)	(ft)	(psi)	(psi)	

**Path No: 9**

A12	17.92	5.6	20.7	1	1x(us.Tee-Br)=5	0.25	120	13.7	
081	17.67		20.7	1.049		5	0.1381	0.1	
						5.25		0.7	
								<b>14.5</b>	

**Path No: 10**

A5	17.92	5.6	20.8	1	1x(us.Tee-Br)=5	0.25	120	13.8	
055	17.67		20.8	1.049		5	0.1398	0.1	
						5.25		0.7	
								<b>14.7</b>	

**Path No: 11**

A10	17.92	5.6	20.8	1	1x(us.Tee-Br)=5	0.25	120	13.8	
064	17.67		20.8	1.049		5	0.1399	0.1	
						5.25		0.7	
								<b>14.7</b>	

**Path No: 12**

A1	17.92	5.6	20.9	1	1x(us.Tee-Br)=5	0.25	120	13.9	
001	17.67		20.9	1.049		5	0.1401	0.1	
						5.25		0.7	
								<b>14.7</b>	

**Path No: 13**

A6	17.92	5.6	20.9	1	1x(us.Tee-Br)=5	0.25	120	13.9	
068	17.67		20.9	1.049		5	0.1403	0.1	
						5.25		0.7	
								<b>14.7</b>	

**Path No: 14**

A15	17.92	5.6	20.9	1	1x(us.Tee-Br)=5	0.25	120	13.9	
078	17.67		20.9	1.049		5	0.1405	0.1	
						5.25		0.7	
								<b>14.8</b>	

**Path No: 15**

A11	17.92	5.6	20.9	1	1x(us.Tee-Br)=5	0.25	120	14	
082	17.67		20.9	1.049		5	0.141	0.1	
						5.25		0.7	
								<b>14.8</b>	

**Path No: 16**

057	17.67		0	1.5		10	120	14.4	
056	17.67		9.6	1.68		0	0.0033	0	
						10		0.0	
								<b>14.4</b>	

### PIPE INFORMATION

Node 1 Node 2	Elev 1 Elev 2	K-Factor 1 K-Factor 2	Flow added (q) Total flow (Q)	Nominal ID Actual ID	Fittings quantity x (name) = length	L F T	C Factor Pf per ft	total (Pt) elev (Pe) frict (Pf)	NOTES
	(ft)	(gpm/psi <sup>1/2</sup> )	(gpm)	(in)	(ft)	(ft)	(psi)	(psi)	

**Path No: 17**

010	14.67		0	1.5	4x(us.Tee-Br)=39.37	110.2	120	19.1	
037	14.67		23.1	1.68		39.37	0.0171	0	
						149.57		2.6	
								<b>21.6</b>	

**Path No: 18**

011	14.67		0	1.5	4x(us.Tee-Br)=39.37	110.2	120	19.3	
036	14.67		22.5	1.68		39.37	0.0163	0	
						149.57		2.4	
								<b>21.7</b>	

**Path No: 19**

012	14.67		0	1.5	4x(us.Tee-Br)=39.37	110.2	120	19.5	
034	14.67		23	1.68		39.37	0.017	0	
						149.57		2.5	
								<b>22</b>	

**Path No: 20**

013	14.67		0	1.5	4x(us.Tee-Br)=39.37	110.2	120	19.5	
033	14.67		22.5	1.68		39.37	0.0163	0	
						149.57		2.4	
								<b>22</b>	

**Path No: 21**

014	14.67		0	1.5	4x(us.Tee-Br)=39.37	110.2	120	19.6	
032	14.67		22.2	1.68		39.37	0.0159	0	
						149.57		2.4	
								<b>22</b>	

**Path No: 22**

015	14.67		0	1.5	4x(us.Tee-Br)=39.37	110.2	120	19.6	
031	14.67		22.1	1.68		39.37	0.0157	0	
						149.57		2.3	
								<b>22</b>	

**Path No: 23**

066	17.67		0	1.5		10	120	14.4	
065	17.67		9.5	1.68		0	0.0033	0	
						10		0.0	
								<b>14.4</b>	

**Path No: 24**

080	17.67		0	1.5		10	120	14.4	
079	17.67		9.2	1.68		0	0.0031	0	
						10		0.0	
								<b>14.5</b>	



### PIPE INFORMATION


Node 1 Node 2	Elev 1 Elev 2	K-Factor 1 K-Factor 2	Flow added (q) Total flow (Q)	Nominal ID Actual ID	Fittings quantity x (name) = length	L F T	C Factor Pf per ft	total (Pt) elev (Pe) frict (Pf)	NOTES
	(ft)	(gpm/psi <sup>1/2</sup> )	(gpm)	(in)	(ft)	(ft)	(psi)	(psi)	

\* Pressures are balanced to a high degree of accuracy. Values may vary by 0.1 psi due to display rounding.


\* Maximum Velocity of 7.77 ft/s occurs in the following pipe(s): (082-A11)

\*\*\* Device pressure loss (gain in the case of pumps) is calculated from the device's curve. If the device curve is printed with this report, it will appear below. The length of the device as shown in the table above comes from the CAD drawing. The friction loss per unit of length is calculated based upon the length and the curve-based loss/gain value. Internal ID and C Factor values are irrelevant as the device is not represented as an addition to any pipe, but is an individual item whose loss/gain is based solely on the curve data.


### Pressure vs. Flow Function Design Area: 1; Supply Ref.: W1; Supply Name:W1




### Pressure Loss Function Design Area: 1; BFP Ref.: 383 (AmesC300N, Size = 6); Inlet Node: 121-I; Outlet Node: 121-O




**Pressure Loss Function**  
**Design Area: 1; Valve Ref.: 384 (Gate A2360, Size = 8); Inlet Node: 128-I; Outlet Node: 128-O**



**Pressure Loss Function**  
**Design Area: 1; Valve Ref.: 385 (Gate A2360, Size = 8); Inlet Node: 127-I; Outlet Node: 127-O**



**Pressure Loss Function**  
**Design Area: 1; Valve Ref.: 386 (Gate A2360, Size = 8); Inlet Node: 130-I; Outlet Node: 130-O**



# CALCULATION SUMMARY

Project Name : Westdell - CRU #1B

Project Location: 1300 Fanshawe Pk Rd East

Contract No. : 062-040424

City: London, Ontario

## Design Areas

Design Area Name	Calc. Mode (Model)	Occupancy	Area of Application	Total Water	Pressure @ Source	Min. Density	Min. Pressure	Min. Flow	Calculated Heads	Hose Streams	Margin To Source
			(ft <sup>2</sup> )	(gpm)	(psi)	(gpm/ft <sup>2</sup> )	(psi)	(gpm)	#	(gpm)	(psi)
2	Demand (HW)	Storage To 17ft	2000	1556.8	Required 43.6	0.28	11.8	27.4	27	800	20.9



# HYDRAULIC CALCULATIONS for

---

## Job Information

Project Name : Westdell - CRU #1B

Contract No. : 062-040424

City: London, Ontario

Project Location: 1300 Fanshawe Pk Rd East

Date: 4/4/2024

---

## Contractor Information

Name of Contractor: SDC

Address: 23 Turnbull Drive

City: Brantford, Ontario N3T 0K4

Phone Number: 226-388-1503

E-mail: jhayhurst@hotmail.ca

Name of Designer: JSH

Authority Having Jurisdiction: Local Bldg Dept.

---

## Design

Remote Area Name	2
Remote Area Location	Back Rm/Loading Dock Area
Occupancy Classification	Storage To 17ft
Density (gpm/ft <sup>2</sup> )	0.28
Area of Application (ft <sup>2</sup> )	2000
Coverage per Sprinkler (ft <sup>2</sup> )	98
Number of Calculated Sprinklers	27
In-Rack Demand (gpm)	0
Special Heads	
Hose Streams (gpm)	800
Total Water Required (incl. Hose Streams) (gpm)	1556.8
Required Pressure at Source (psi)	43.6
Type of System	Wet
Volume - Entire System (gal)	1974.1 gal

---


## Water Supply Information

Date	Nov.2015
Location	1300 Fanshawe Pk Rd E
Source	W1

---

## Notes

### Diagram for Design Area : 2 (Optimized Hvdraulic Simplified)



## Hydraulic Analysis for : 2

### Calculation Info

Calculation Mode	Demand
Hydraulic Model	Hazen-Williams
Fluid Name	Water @ 60F (15.6C)
Fluid Weight, (lb/ft <sup>3</sup> )	N/A for Hazen-Williams calculation.
Fluid Dynamic Viscosity, (lb-s/ft <sup>2</sup> )	N/A for Hazen-Williams calculation.

### Water Supply Parameters

Supply 1 : W1

Flow (gpm)	Pressure (psi)
0	68
1160	65
1840	64

### Supply Analysis

Node at Source	Static Pressure (psi)	Residual Pressure (psi)	Flow (gpm)	Available Pressure (psi)	Total Demand (gpm)	Required Pressure (psi)
W1	68	65	1160	64.5	1556.8	43.6

### Hoses

Inside Hose Flow / Standpipe Demand (gpm)	400
Outside Hose Flow (gpm)	0
Additional Outside Hose Flow (gpm)	400
Other (custom defined) Hose Flow (gpm)	0
<hr style="border-top: 1px dashed black;"/>	
Total Hose Flow (gpm)	800

### Sprinklers


Ovehead Sprinkler Flow (gpm)	756.8
InRack Sprinkler Flow (gpm)	0
Other (custom defined) Sprinkler Flow (gpm)	0
<hr style="border-top: 1px dashed black;"/>	
Total Sprinkler Flow (gpm)	756.8

### Other

Required Margin of Safety (psi)	0
W1 - Pressure (psi)	43.6
W1 - Flow (gpm)	1156.8
Demand w/o System Pump(s)	N/A



### Hydraulic Analysis for : 2



## Hydraulic Analysis for : 2

### Graph Labels

Label	Description	Values	
		Flow (gpm)	Pressure (psi)
S1	Supply point #1 - Static	0	68
S2	Supply point #2	1160	65
S3	Supply point #3	1840	64
D1	Elevation Pressure	0	10.3
D2	System Demand	1156.8	43.6
D3	System Demand + Add.Out.Hose	1556.8	43.6

### Curve Intersections & Safety Margins

Curve Name	Intersection		Safety Margin	
	Pressure (psi)	Flow (gpm)	Pressure (psi)	@ Flow (gpm)
Supply	64.5	1506.4	20.9	1556.8

### Open Heads

Head Ref.	Head Type	Coverage	K-Factor	Required			Calculated		
				Density	Flow	Pressure	Density	Flow	Pressure
		(ft <sup>2</sup> )	(gpm/psi <sup>1/2</sup> )	(gpm/ft <sup>2</sup> )	(gpm)	(psi)	(gpm/ft <sup>2</sup> )	(gpm)	(psi)
B1	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.281	27.5	11.8
B10	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.282	27.6	11.9
B11	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.284	27.8	12.1
B12	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.295	28.9	13
B13	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.28	27.4	11.8
B14	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.282	27.6	11.9
B15	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.293	28.8	12.9
B16	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.28	27.4	11.8
B17	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.282	27.6	11.9
B18	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.294	28.8	12.9
B19	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.28	27.5	11.8
B2	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.283	27.7	12

B20	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.282	27.7	12
B21	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.294	28.8	13
B22	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.281	27.6	11.9
B23	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.283	27.7	12
B24	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.294	28.8	13
B25	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.282	27.6	11.9
B26	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.284	27.8	12.1
B27	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.295	28.9	13
B3	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.294	28.8	13
B4	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.281	27.5	11.8
B5	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.283	27.7	12
B6	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.294	28.8	13
B7	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.281	27.6	11.9
B8	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.283	27.8	12
B9	Overhead Sprinkler	98	8	0.28	27.4	11.8	0.294	28.9	13

### Node Data

Node# Elev	Type Hgroup	K-Fact. Open/Closed	Discharge Overdischarge	Coverage Density	Tot. Pres. Elev. Pres.	Req. Pres. Req. Discharge
ft		gpm/psi <sup>1/2</sup>	gpm gpm	ft <sup>2</sup> gpm/ft <sup>2</sup>	psi psi	psi gpm
B13 17.67	Overhead Sprinkler HEAD	8 Open	27.4 0	98 0.28	11.8 -10.3	11.8 27.4
B16 17.67	Overhead Sprinkler HEAD	8 Open	27.4 0	98 0.28	11.8 -10.3	11.8 27.4
B19 17.67	Overhead Sprinkler HEAD	8 Open	27.5 0.0	98 0.28	11.8 -10.3	11.8 27.4
B1 17.67	Overhead Sprinkler HEAD	8 Open	27.5 0.1	98 0.281	11.8 -10.3	11.8 27.4
B4 17.67	Overhead Sprinkler HEAD	8 Open	27.5 0.1	98 0.281	11.8 -10.3	11.8 27.4
B22 17.67	Overhead Sprinkler HEAD	8 Open	27.6 0.1	98 0.281	11.9 -10.3	11.8 27.4
B7 17.67	Overhead Sprinkler HEAD	8 Open	27.6 0.1	98 0.281	11.9 -10.3	11.8 27.4
B14 17.67	Overhead Sprinkler HEAD	8 Open	27.6 0.2	98 0.282	11.9 -10.3	11.8 27.4
B25 17.67	Overhead Sprinkler HEAD	8 Open	27.6 0.2	98 0.282	11.9 -10.3	11.8 27.4
B17 17.67	Overhead Sprinkler HEAD	8 Open	27.6 0.2	98 0.282	11.9 -10.3	11.8 27.4
B10 17.67	Overhead Sprinkler HEAD	8 Open	27.6 0.2	98 0.282	11.9 -10.3	11.8 27.4
B20 17.67	Overhead Sprinkler HEAD	8 Open	27.7 0.2	98 0.282	12 -10.3	11.8 27.4
B2 17.67	Overhead Sprinkler HEAD	8 Open	27.7 0.3	98 0.283	12 -10.3	11.8 27.4
B5 17.67	Overhead Sprinkler HEAD	8 Open	27.7 0.3	98 0.283	12 -10.3	11.8 27.4
B23 17.67	Overhead Sprinkler HEAD	8 Open	27.7 0.3	98 0.283	12 -10.3	11.8 27.4
B8 17.67	Overhead Sprinkler HEAD	8 Open	27.8 0.3	98 0.283	12 -10.3	11.8 27.4
B26 17.67	Overhead Sprinkler HEAD	8 Open	27.8 0.4	98 0.284	12.1 -10.3	11.8 27.4
B11 17.67	Overhead Sprinkler HEAD	8 Open	27.8 0.4	98 0.284	12.1 -10.3	11.8 27.4
B15 17.67	Overhead Sprinkler HEAD	8 Open	28.8 1.3	98 0.293	12.9 -10.3	11.8 27.4
B18 17.67	Overhead Sprinkler HEAD	8 Open	28.8 1.3	98 0.294	12.9 -10.3	11.8 27.4
B21 17.67	Overhead Sprinkler HEAD	8 Open	28.8 1.4	98 0.294	13 -10.3	11.8 27.4
B3 17.67	Overhead Sprinkler HEAD	8 Open	28.8 1.4	98 0.294	13 -10.3	11.8 27.4
B6 17.67	Overhead Sprinkler HEAD	8 Open	28.8 1.4	98 0.294	13 -10.3	11.8 27.4
B24 17.67	Overhead Sprinkler HEAD	8 Open	28.8 1.4	98 0.294	13 -10.3	11.8 27.4
B9 17.67	Overhead Sprinkler HEAD	8 Open	28.9 1.4	98 0.294	13 -10.3	11.8 27.4

### Node Data

Node# Elev	Type Hgroup	K-Fact. Open/Closed	Discharge Overdischarge	Coverage Density	Tot. Pres. Elev. Pres.	Req. Pres. Req. Discharge
ft		gpm/psi <sup>1/2</sup>	gpm gpm	ft <sup>2</sup> gpm/ft <sup>2</sup>	psi psi	psi gpm
B27 17.67	Overhead Sprinkler HEAD	8 Open	28.9 1.4	98 0.295	13 -10.3	11.8 27.4
B12 17.67	Overhead Sprinkler HEAD	8 Open	28.9 1.4	98 0.295	13 -10.3	11.8 27.4
029 17.67	Node NODE				13.2 -10.3	
207 17.67	Node NODE				13.2 -10.3	
193 17.67	Node NODE				13.2 -10.3	
059 17.67	Node NODE				13.2 -10.3	
073 17.67	Node NODE				13.2 -10.3	
177 17.67	Node NODE				13.3 -10.3	
087 17.67	Node NODE				13.3 -10.3	
161 17.67	Node NODE				13.3 -10.3	
101 17.67	Node NODE				13.4 -10.3	
016 14.67	Node NODE				14.3 -9	
015 14.67	Node NODE				14.3 -9	
014 14.67	Node NODE				14.3 -9	
013 14.67	Node NODE				14.3 -9	
012 14.67	Node NODE				14.3 -9	
011 14.67	Node NODE				14.3 -9	
010 14.67	Node NODE				14.3 -9	
009 14.67	Node NODE				14.3 -9	
008 14.67	Node NODE				14.4 -9	
006 14.67	Node NODE				14.4 -9	
030 14.67	Node NODE				16.6 -9	
031 14.67	Node NODE				16.6 -9	
032 14.67	Node NODE				16.7 -9	
040 14.67	Node NODE				16.8 -9	

### Node Data

Node# Elev	Type Hgroup	K-Fact. Open/Closed	Discharge Overdischarge	Coverage Density	Tot. Pres. Elev. Pres.	Req. Pres. Req. Discharge
ft		gpm/psi <sup>1/2</sup>	gpm gpm	ft <sup>2</sup> gpm/ft <sup>2</sup>	psi psi	psi gpm
039 14.67	Node NODE				16.8 -9	
038 14.67	Node NODE				16.8 -9	
033 14.67	Node NODE				16.9 -9	
037 14.67	Node NODE				16.9 -9	
036 14.67	Node NODE				17.1 -9	
034 14.67	Node NODE				17.1 -9	
035 14.67	Node NODE				18.1 -9	
117 3.5	Node NODE				31 -4.1	
121-O 0.54	Node NODE				33.7 -2.8	
121-I -2.5	Node NODE				39.3 -1.5	
122 -5.33	Node NODE				40.6 -0.3	
127-O -6	Node NODE				42.9 0	
127-I -6	Node NODE				42.9 0	
128-O -6	Node NODE				43.1 0	
128-I -6	Node NODE				43.1 0	
130-O -6	Node NODE				43.5 0	
130-I -6	Node NODE				43.5 0	
H1 -6	Inside Hose HOSE		400		43.6 0	400
W1 -6	Supply SUPPLY		-1156.8		43.6 0	

### PIPE INFORMATION

Node 1 Node 2	Elev 1 Elev 2	K-Factor 1 K-Factor 2	Flow added (q) Total flow (Q)	Nominal ID Actual ID	Fittings quantity x (name) = length	L F T	C Factor Pf per ft	total (Pt) elev (Pe) frict (Pf)	NOTES
	(ft)	(gpm/psi <sup>1/2</sup> )	(gpm)	(in)	(ft)	(ft)	(psi)	(psi)	

**Path No: 1**

B13 B14	17.67 17.67	8 8	27.4 27.4	1.5 1.68		7.02 0 7.02	120 0.0235	11.8 0 0.2	
B14 029	17.67 17.67	8	27.6 55.1	1.5 1.68	1x(us.Tee-Br)=9.84	4.53 9.84 14.37	120 0.0854	11.9 0 1.2	
029 030	17.67 14.67		24.4 79.5	1.5 1.68	1x(us.Tee-Br)=9.84	3 9.84 12.84	120 0.1686	13.2 1.3 2.2	
030 031	14.67 14.67		0 79.5	4 4.26		10.23 0 10.23	120 0.0018	16.6 0 0.0	
031 032	14.67 14.67		79.7 159.2	4 4.26		10.23 0 10.23	120 0.0066	16.6 0 0.1	
032 033	14.67 14.67		80.4 239.6	4 4.26		10.23 0 10.23	120 0.014	16.7 0 0.1	
033 034	14.67 14.67		81.9 321.4	4 4.26		9.44 0 9.44	120 0.0241	16.9 0 0.2	
034 035	14.67 14.67		84.6 406	4 4.26	1x(us.Tee-Br)=26.33	1.69 26.33 28.02	120 0.0372	17.1 0 1	
035 117	14.67 3.5		350.8 756.8	4 4.26	1x(us.Tee-Br)=26.33 1x(us.90)=13.17	28.92 39.5 68.42	120 0.1178	18.1 4.8 8.1	
117 121-O	3.5 0.54		0 756.8	6 6.357	1x(us.Tee-Br)=37.72 2x(us.90)=35.21	12.46 72.93 85.38	120 0.0168	31 1.3 1.4	
121-O 121-I	0.54 -2.5		0 756.8	6 0		3.04 0 3.04	1.3888	33.7 1.3 4.2	AmesC300N ***
121-I 122	-2.5 -5.33		0 756.8	6 6.357		2.83 0 2.83	120 0.0168	39.3 1.2 0.0	
122 127-O	-5.33 -6		0 756.8	8 7.98	3x(us.45)=38.58 1x(us.90)=25.72	494.84 64.3 559.14	150 0.0037	40.6 0.3 2	
127-O 127-I	-6 -6		0 756.8	8 0		0.96 0 0.96	0.0072	42.9 0 0	Gate A2360 ***
127-I 128-O	-6 -6		0 756.8	8 7.98		60.29 0 60.29	150 0.0037	42.9 0 0.2	
128-O 128-I	-6 -6		0 756.8	8 0		0.96 0 0.96	0.0072	43.1 0 0	Gate A2360 ***

### PIPE INFORMATION

Node 1 Node 2	Elev 1 Elev 2	K-Factor 1 K-Factor 2	Flow added (q) Total flow (Q)	Nominal ID Actual ID	Fittings quantity x (name) = length	L F T	C Factor Pf per ft	total (Pt) elev (Pe) frict (Pf)	NOTES
	(ft)	(gpm/psi <sup>1/2</sup> )	(gpm)	(in)	(ft)	(ft)	(psi)	(psi)	

**Path No: 1**

128-I	-6		0	8	1x(us.90)=25.72	86.51	150	43.1	
130-O	-6		756.8	7.98		25.72	0.0037	0	
						112.23		0.4	
130-O	-6		0	8		0.96		43.5	Gate A2360
130-I	-6		756.8	0		0	0.0072	0	***
						0.96		0	
130-I	-6		0	8		3.33	150	43.5	
H1	-6		756.8	7.98		0	0.0037	0	
						3.33		0.0	
H1	-6		400	8		0.67	150	43.6	
W1	-6		1156.8	7.98		0	0.008	0	
						0.67		0	
<b>W1</b>								<b>43.6</b>	

**Path No: 2**

B16	17.67	8	27.4	1.5		7.01	120	11.8	
B17	17.67	8	27.4	1.68		0	0.0235	0	
						7.01		0.2	
B17	17.67	8	27.6	1.5	1x(us.Tee-Br)=9.84	4.54	120	11.9	
207	17.67		55.1	1.68		9.84	0.0854	0	
						14.39		1.2	
207	17.67		24.6	1.5	1x(us.Tee-Br)=9.84	3	120	13.2	
031	14.67		79.7	1.68		9.84	0.1693	1.3	
						12.84		2.2	
<b>031</b>								<b>16.6</b>	

**Path No: 3**

B19	17.67	8	27.5	1.5		7	120	11.8	
B20	17.67	8	27.5	1.68		0	0.0236	0	
						7		0.2	
B20	17.67	8	27.7	1.5	1x(us.Tee-Br)=9.84	4.55	120	12	
193	17.67		55.2	1.68		9.84	0.0856	0	
						14.4		1.2	
193	17.67		25.2	1.5	1x(us.Tee-Br)=9.84	3	120	13.2	
032	14.67		80.4	1.68		9.84	0.1719	1.3	
						12.84		2.2	
<b>032</b>								<b>16.7</b>	



### PIPE INFORMATION

Node 1 Node 2	Elev 1 Elev 2	K-Factor 1 K-Factor 2	Flow added (q) Total flow (Q)	Nominal ID Actual ID	Fittings quantity x (name) = length	L F T	C Factor Pf per ft	total (Pt) elev (Pe) frict (Pf)	NOTES
	(ft)	(gpm/psi <sup>1/2</sup> )	(gpm)	(in)	(ft)	(ft)	(psi)	(psi)	

**Path No: 4**

B1	17.67	8	27.5	1.5		7	120	11.8	
B2	17.67	8	27.5	1.68		0	0.0236	0	
						7		0.2	
B2	17.67	8	27.7	1.5	1x(us.Tee-Br)=9.84	4.55	120	12	
059	17.67		55.2	1.68		9.84	0.0859	0	
						14.4		1.2	
059	17.67		25.3	1.5	1x(us.Tee-Br)=9.84	3	120	13.2	
039	14.67		80.6	1.68		9.84	0.1727	1.3	
						12.84		2.2	
039	14.67		23.1	4		10.27	120	16.8	
038	14.67		103.6	4.26		0	0.003	0	
						10.27		0.0	
038	14.67		80.9	4		9.51	120	16.8	
037	14.67		184.5	4.26		0	0.0086	0	
						9.51		0.1	
037	14.67		81.8	4		12.25	120	16.9	
036	14.67		266.3	4.26		0	0.017	0	
						12.25		0.2	
036	14.67		84.5	4	1x(us.Tee-Br)=26.33	10.56	120	17.1	
035	14.67		350.8	4.26		26.33	0.0284	0	
						36.89		1	
<b>035</b>								<b>18.1</b>	

**Path No: 5**

B4	17.67	8	27.5	1.5		7	120	11.8	
B5	17.67	8	27.5	1.68		0	0.0237	0	
						7		0.2	
B5	17.67	8	27.7	1.5	1x(us.Tee-Br)=9.84	4.55	120	12	
073	17.67		55.3	1.68		9.84	0.0859	0	
						14.4		1.2	
073	17.67		25.7	1.5	1x(us.Tee-Br)=9.84	3	120	13.2	
038	14.67		80.9	1.68		9.84	0.1741	1.3	
						12.84		2.2	
<b>038</b>								<b>16.8</b>	

**Path No: 6**

B22	17.67	8	27.6	1.5		7.01	120	11.9	
B23	17.67	8	27.6	1.68		0	0.0237	0	
						7.01		0.2	
B23	17.67	8	27.7	1.5	1x(us.Tee-Br)=9.84	4.54	120	12	
177	17.67		55.3	1.68		9.84	0.086	0	
						14.39		1.2	
177	17.67		26.6	1.5	1x(us.Tee-Br)=9.84	3	120	13.3	
033	14.67		81.9	1.68		9.84	0.1779	1.3	
						12.84		2.3	
<b>033</b>								<b>16.9</b>	

### PIPE INFORMATION

Node 1 Node 2	Elev 1 Elev 2	K-Factor 1 K-Factor 2	Flow added (q) Total flow (Q)	Nominal ID Actual ID	Fittings quantity x (name) = length	L F T	C Factor Pf per ft	total (Pt) elev (Pe) frict (Pf)	NOTES
	(ft)	(gpm/psi <sup>1/2</sup> )	(gpm)	(in)	(ft)	(ft)	(psi)	(psi)	

**Path No: 7**

B7	17.67	8	27.6	1.5		7	120	11.9	
B8	17.67	8	27.6	1.68		0	0.0237	0	
						7		0.2	
B8	17.67	8	27.8	1.5	1x(us.Tee-Br)=9.84	4.55	120	12	
087	17.67		55.3	1.68		9.84	0.0861	0	
						14.4		1.2	
087	17.67		26.5	1.5	1x(us.Tee-Br)=9.84	3	120	13.3	
037	14.67		81.8	1.68		9.84	0.1778	1.3	
						12.84		2.3	
<b>037</b>								<b>16.9</b>	

**Path No: 8**

B25	17.67	8	27.6	1.5		7	120	11.9	
B26	17.67	8	27.6	1.68		0	0.0238	0	
						7		0.2	
B26	17.67	8	27.8	1.5	1x(us.Tee-Br)=9.84	4.55	120	12.1	
161	17.67		55.5	1.68		9.84	0.0865	0	
						14.4		1.2	
161	17.67		29.1	1.5	1x(us.Tee-Br)=9.84	3	120	13.3	
034	14.67		84.6	1.68		9.84	0.1892	1.3	
						12.84		2.4	
<b>034</b>								<b>17.1</b>	

**Path No: 9**

B10	17.67	8	27.6	1.5		7	120	11.9	
B11	17.67	8	27.6	1.68		0	0.0238	0	
						7		0.2	
B11	17.67	8	27.8	1.5	1x(us.Tee-Br)=9.84	4.55	120	12.1	
101	17.67		55.5	1.68		9.84	0.0866	0	
						14.4		1.2	
101	17.67		29	1.5	1x(us.Tee-Br)=9.84	3	120	13.4	
036	14.67		84.5	1.68		9.84	0.1885	1.3	
						12.84		2.4	
<b>036</b>								<b>17.1</b>	

**Path No: 10**

B15	17.67	8	28.8	1.5	1x(us.Tee-Br)=9.84	2.45	120	12.9	
029	17.67		24.4	1.68		9.84	0.019	0	
						12.29		0.2	
<b>029</b>								<b>13.2</b>	

### PIPE INFORMATION

Node 1 Node 2	Elev 1 Elev 2	K-Factor 1 K-Factor 2	Flow added (q) Total flow (Q)	Nominal ID Actual ID	Fittings quantity x (name) = length	L F T	C Factor Pf per ft	total (Pt) elev (Pe) frict (Pf)	NOTES
	(ft)	(gpm/psi <sup>1/2</sup> )	(gpm)	(in)	(ft)	(ft)	(psi)	(psi)	

**Path No: 11**

B15 016	17.67 14.67	8	28.8 4.3	1.5 1.68	2x(us.Tee-Br)=19.68	104.76 19.68 124.44	120 0.0008	12.9 1.3 0.1	
016 015	14.67 14.67		0 4.3	3 3.26		10.23 0 10.23	120 0.0000	14.3 0 0	
015 014	14.67 14.67		4.2 8.5	3 3.26		10.23 0 10.23	120 0.0001	14.3 0 0	
014 013	14.67 14.67		3.6 12.1	3 3.26		10.23 0 10.23	120 0.0002	14.3 0 0	
013 012	14.67 14.67		2.3 14.4	3 3.26		9.44 0 9.44	120 0.0003	14.3 0 0	
012 011	14.67 14.67		-0.3 14.1	3 3.26	1x(us.Tee-Br)=20.16	12.25 20.16 32.41	120 0.0003	14.3 0 0	
011 010	14.67 14.67		-0.1 14	3 3.26	1x(us.Tee-Br)=20.16	12.25 20.16 32.41	120 0.0003	14.3 0 0	
010 009	14.67 14.67		2.4 16.4	3 3.26		9.51 0 9.51	120 0.0004	14.3 0 0	
009 008	14.67 14.67		3.2 19.5	3 3.26		10.27 0 10.27	120 0.0005	14.3 0 0	
008 006	14.67 14.67		3.5 23.1	3 3.26	1x(us.Tee-Br)=20.16	10.27 20.16 30.43	120 0.0007	14.4 0 0.0	
006 040	14.67 14.67		0 23.1	1.5 1.68	3x(us.Tee-Br)=29.53	110.2 29.53 139.73	120 0.017	14.4 0 2.4	
040 039	14.67 14.67		0 23.1	4 4.26		10.27 0 10.27	120 0.0002	16.8 0 0	
<b>039</b>								<b>16.8</b>	

**Path No: 12**

B18 207	17.67 17.67	8	28.8 24.6	1.5 1.68	1x(us.Tee-Br)=9.84	2.44 9.84 12.28	120 0.0192	12.9 0 0.2	
<b>207</b>								<b>13.2</b>	

**Path No: 13**

B18 015	17.67 14.67	8	28.8 4.2	1.5 1.68	2x(us.Tee-Br)=19.68	104.77 19.68 124.45	120 0.0007	12.9 1.3 0.1	
<b>015</b>								<b>14.3</b>	

### PIPE INFORMATION

Node 1 Node 2	Elev 1 Elev 2	K-Factor 1 K-Factor 2	Flow added (q) Total flow (Q)	Nominal ID Actual ID	Fittings quantity x (name) = length	L F T	C Factor Pf per ft	total (Pt) elev (Pe) frict (Pf)	NOTES
	(ft)	(gpm/psi <sup>1/2</sup> )	(gpm)	(in)	(ft)	(ft)	(psi)	(psi)	

**Path No: 14**

B21	17.67	8	28.8	1.5	1x(us.Tee-Br)=9.84	2.42	120	13	
193	17.67		25.2	1.68		9.84	0.0201	0	
						12.27		0.2	
<b>193</b>								<b>13.2</b>	

**Path No: 15**

B21	17.67	8	28.8	1.5	2x(us.Tee-Br)=19.68	104.78	120	13	
014	14.67		3.6	1.68		19.68	0.0005	1.3	
						124.46		0.1	
<b>014</b>								<b>14.3</b>	

**Path No: 16**

B3	17.67	8	28.8	1.5	1x(us.Tee-Br)=9.84	2.41	120	13	
059	17.67		25.3	1.68		9.84	0.0203	0	
						12.26		0.2	
<b>059</b>								<b>13.2</b>	

**Path No: 17**

B3	17.67	8	28.8	1.5	2x(us.Tee-Br)=19.68	104.79	120	13	
008	14.67		3.5	1.68		19.68	0.0005	1.3	
						124.47		0.1	
<b>008</b>								<b>14.4</b>	

**Path No: 18**

B6	17.67	8	28.8	1.5	1x(us.Tee-Br)=9.84	2.41	120	13	
073	17.67		25.7	1.68		9.84	0.0208	0	
						12.26		0.3	
<b>073</b>								<b>13.2</b>	

**Path No: 19**

B6	17.67	8	28.8	1.5	2x(us.Tee-Br)=19.68	104.79	120	13	
009	14.67		3.2	1.68		19.68	0.0004	1.3	
						124.47		0.1	
<b>009</b>								<b>14.3</b>	

**Path No: 20**

B24	17.67	8	28.8	1.5	1x(us.Tee-Br)=9.84	2.42	120	13	
177	17.67		26.6	1.68		9.84	0.0221	0	
						12.27		0.3	
<b>177</b>								<b>13.3</b>	

**Path No: 21**

B24	17.67	8	28.8	1.5	2x(us.Tee-Br)=19.68	104.78	120	13	
013	14.67		2.3	1.68		19.68	0.0002	1.3	
						124.46		0.0	
<b>013</b>								<b>14.3</b>	

### PIPE INFORMATION

Node 1 Node 2	Elev 1 Elev 2	K-Factor 1 K-Factor 2	Flow added (q) Total flow (Q)	Nominal ID Actual ID	Fittings quantity x (name) = length	L F T	C Factor Pf per ft	total (Pt) elev (Pe) frict (Pf)	NOTES
	(ft)	(gpm/psi <sup>1/2</sup> )	(gpm)	(in)	(ft)	(ft)	(psi)	(psi)	

**Path No: 22**

B9	17.67	8	28.9	1.5	1x(us.Tee-Br)=9.84	2.42	120	13	
087	17.67		26.5	1.68		9.84	0.022	0	
						12.26		0.3	
								<b>13.3</b>	

**Path No: 23**

B9	17.67	8	28.9	1.5	2x(us.Tee-Br)=19.68	104.79	120	13	
010	14.67		2.4	1.68		19.68	0.0003	1.3	
						124.47		0.0	
								<b>14.3</b>	

**Path No: 24**

B27	17.67	8	28.9	1.5	1x(us.Tee-Br)=9.84	2.42	120	13	
161	17.67		29.1	1.68		9.84	0.0263	0	
						12.26		0.3	
								<b>13.3</b>	

**Path No: 25**

B12	17.67	8	28.9	1.5	1x(us.Tee-Br)=9.84	2.42	120	13	
101	17.67		29	1.68		9.84	0.026	0	
						12.26		0.3	
								<b>13.4</b>	

**Path No: 26**

012	14.67		0	1.5	2x(us.Tee-Br)=19.68	104.79	120	14.3	
B27	17.67	8	0.3	1.68		19.68	0	-1.3	
						124.47		0	
								<b>13</b>	

**Path No: 27**


011	14.67		0	1.5	1x(us.Tee-Br)=9.84	104.79	120	14.3	
B12	17.67	8	0.1	1.68		9.84	0	-1.3	
						114.63		0	
								<b>13</b>	

\* Pressures are balanced to a high degree of accuracy. Values may vary by 0.1 psi due to display rounding.


\* Maximum Velocity of 17.04 ft/s occurs in the following pipe(s): (117-035)

\*\*\* Device pressure loss (gain in the case of pumps) is calculated from the device's curve. If the device curve is printed with this report, it will appear below. The length of the device as shown in the table above comes from the CAD drawing. The friction loss per unit of length is calculated based upon the length and the curve-based loss/gain value. Internal ID and C Factor values are irrelevant as the device is not represented as an addition to any pipe, but is an individual item whose loss/gain is based solely on the curve data.


**Pressure vs. Flow Function**  
**Design Area: 2; Supply Ref.: W1; Supply Name:W1**




**Pressure Loss Function**  
**Design Area: 2; BFP Ref.: 383 (AmesC300N, Size = 6); Inlet Node: 121-I; Outlet Node: 121-O**



**Pressure Loss Function**  
**Design Area: 2; Valve Ref.: 384 (Gate A2360, Size = 8); Inlet Node: 128-I; Outlet Node: 128-O**



**Pressure Loss Function**  
**Design Area: 2; Valve Ref.: 385 (Gate A2360, Size = 8); Inlet Node: 127-I; Outlet Node: 127-O**



**Pressure Loss Function**  
**Design Area: 2; Valve Ref.: 386 (Gate A2360, Size = 8); Inlet Node: 130-I; Outlet Node: 130-O**

